

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 182 00 Praha 8, Troja

## CERTIFICATE

No.: 1230410

Product: Electrical insulating matting

Type: DEK4-H-1

Rating: Class 4

Ordering firm: BOGUMA, s. r. o.  
Továrenská 314, 956 01 Bošava, Slovakia

Manufacturer: BOGUMA, s. r. o.  
Továrenská 314, 956 01 Bošava, Slovakia

Trade mark:

The test results are stated in the test-report No.: 232047-01/01 of: 04.09.2023

A sample of the product was found to be in conformity with:

ČSN EN 611:2010 (idt. IEC 61111:2009)

cl. 5.2.2, 5.2.5, 5.3, 5.5.2, 5.5.3, 5.6.2.2, 5.6.2.3, 5.6.4.2, 5.6.4.3, 5.7, 5.8.1, 5.8.2, 5.9, 5.10

Other data:


The validity of the certificate is limited to: 07.09.2026

08.09.2023

Prague



Mgr. Miroslav Sedláček  
Head of Certification Body



Stamp



232047-01